

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1209:123 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Models SS12, SS24, SS12LO, SS24LO, SS12M, SS24M, PS412, PS424, PS12M, PS24M, PS12MW, PS12LO, PS12LOW, PS24LO and PS24LOW strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control unit. Each SS- Series strobe may be mounted to listee's separately listed Model MA12/24D and MA12/24 EH sounder (CSFM Listing No. 7135-1209:124). Approved for outdoor use when used in conjunction with model WBB backbox. Not suitable for the hearing impaired application.

NOTE: Formerly 7300-0087:123

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**